

**MATERIAL
SAFETY
DATA SHEET**

PRODUCT NAME Carbon Dioxide	CAS # 124-38-9
TRADE NAME AND SYNONYMS Carbon Dioxide; Carbonic Anhydride	DOT I.D. No.: UN 1013
	DOT Hazard Class: Division 2.2
CHEMICAL NAME AND SYNONYMS Carbon Dioxide	Formula CO ₂
	Chemical Family: Carbonate
ISSUE DATES AND REVISIONS Revised January 1995	

HEALTH HAZARD DATA

TIME WEIGHTED AVERAGE EXPOSURE LIMIT 5,000 Molar PPM; STEL = 30,000 Molar PPM (ACGIH 1994-1995). OSHA 1993 PEL (8 Hr. TWA) = 5,000 Molar PPM .
SYMPTOMS OF EXPOSURE Inhalation: Low concentrations (3-5 molar %) cause increased respiration and headache. Eight to 15 molar % concentrations cause headache, nausea and vomiting which may lead to unconsciousness if not moved to open air or given oxygen. High concentrations cause rapid circulatory insufficiency leading to coma and death.
TOXICOLOGICAL PROPERTIES Carbon dioxide is the most powerful cerebral vasodilator known. Inhaling large concentrations causes rapid circulatory insufficiency leading to coma and death. Chronic, harmful effects are not known from repeated inhalation of low (3-5 molar %) concentrations. Carbon dioxide is not listed in the IARC, NTP or by OSHA as a carcinogen or potential carcinogen. Persons in ill health where such illness would be aggravated by exposure to carbon dioxide should not be allowed to work with or handle this product.
RECOMMENDED FIRST AID TREATMENT PROMPT MEDICAL ATTENTION IS MANDATORY IN ALL CASES OF OVEREXPOSURE TO CARBON DIOXIDE. RESCUE PERSONNEL SHOULD BE EQUIPPED WITH SELF-CONTAINED BREATHING APPARATUS. <u>Inhalation:</u> Conscious persons should be assisted to an uncontaminated area and inhale fresh air. Quick removal from the contaminated area is most important. Unconscious persons should be moved to an uncontaminated area, given assisted respiration and supplemental oxygen. Assure that vomited material does not obstruct the airway by use of positional drainage. Further treatment should be symptomatic and supportive.

Information contained in this material safety data sheet is offered without charge for use by technically qualified personnel at their discretion and risk. All statements, technical information and recommendations contained herein are based on tests and data which we believe to be reliable, but the accuracy or completeness thereof is not guaranteed and no warranty of any kind is made with respect thereto. This information is not intended as a license to operate under or a recommendation to practice or infringe any patent of this Company or others covering any process, composition of matter or use.
Since the Company shall have no control of the use of the product described herein, the Company assumes no liability for loss or damage incurred from the proper or improper use of such product.

HAZARDOUS MIXTURES OF OTHER LIQUIDS, SOLIDS, OR GASES

Forms carbonic acid in the presence of water

PHYSICAL DATA

BOILING POINT Sublimation point = -109.3°F (-78.5°C)	LIQUID DENSITY AT BOILING POINT Solid Density = 97.5 lb/ft ³ (1562 kg/m ³)
VAPOR PRESSURE @ 70°F (21.1°C) = 856 psia (5900 kPa)	GAS DENSITY AT 70°F, 1 atm .124 lb/ft ³ (1.99 kg/m ³)
SOLUBILITY IN WATER Very Soluble	FREEZING POINT -69.8°F (-56.6°C) @ 75.1 psia (518 kPa)
EVAPORATION RATE N/A (Gas)	SPECIFIC GRAVITY (AIR=1) @ 70°F (21.1°C) = 1.65
APPEARANCE AND ODOR Colorless, odorless gas	

FIRE AND EXPLOSION HAZARD DATA

FLASH POINT (Method used) N/A	AUTO IGNITION TEMPERATURE N/A	FLAMMABLE LIMITS % BY VOLUME (See Page 4) LEL N/A UEL N/A	
EXTINGUISHING MEDIA Nonflammable, inert gas		ELECTRICAL CLASSIFICATION Nonhazardous	
SPECIAL FIRE FIGHTING PROCEDURES None			
UNUSUAL FIRE AND EXPLOSION HAZARDS If cylinders are involved in a fire, safely relocate or keep cool with water spray.			

REACTIVITY DATA

STABILITY Unstable		CONDITIONS TO AVOID None
Stable	X	
INCOMPATIBILITY (Materials to avoid) None		
HAZARDOUS DECOMPOSITION PRODUCTS Carbon Monoxide		
HAZARDOUS POLYMERIZATION May Occur		CONDITIONS TO AVOID
Will Not Occur	X	None

SPILL OR LEAK PROCEDURES**STEPS TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED**

Evacuate all personnel from a affected area. Use appropriate protective equipment. If leak is in user's equipment, be certain to purge piping with an inert gas prior to attempting repairs. If leak is in container or container valve, contact your closest supplier location or call the emergency telephone number listed herein.

WASTE DISPOSAL METHOD

Do not attempt to dispose of waste or unused quantities. Return in the shipping container properly labeled, with any valve outlet plugs or caps secured and valve protection cap in place to your supplier for proper disposal. For emergency disposal, contact your closest supplier location or call the emergency telephone number listed herein.

SPECIAL PROTECTION INFORMATION

RESPIRATORY PROTECTION (Specify type)		Positive pressure air line with mask or self-contained breathing apparatus should be available for emergency use. (Continued on Page 4)	
VENTILATION See Local Exhaust	LOCAL EXHAUST To prevent accumulation above the TWA	SPECIAL	N/A
	MECHANICAL (Gen.) N/A	OTHER	N/A
PROTECTIVE GLOVES Any Material			
EYE PROTECTION Safety goggles or glasses			
OTHER PROTECTIVE EQUIPMENT Safety shoes			

SPECIAL PRECAUTIONS*

SPECIAL LABELING INFORMATION			
DOT Shipping Name:	Carbon Dioxide	DOT Hazard Class:	Division 2.2
DOT Shipping Label:	Nonflammable gas	I.D. No.:	UN 1013
SPECIAL HANDLING RECOMMENDATIONS			
<p>Use only in well-ventilated areas. Valve protection caps must remain in place unless container is secured with valve outlet piped to use point. Do not drag, slide or roll cylinders. Use a suitable hand truck for cylinder movement. Use a pressure reducing regulator when connecting cylinder to lower pressure (<1500 psig) piping or systems. Do not heat cylinder by any means to increase the discharge rate of product from the cylinder. Use a check valve or trap in the discharge line to prevent hazardous back flow into the cylinder.</p> <p>For additional handling recommendations, consult Compressed Gas Association's Pamphlets P-1, G-6, G-6.1, and G-6.2.</p>			
SPECIAL STORAGE RECOMMENDATIONS			
<p>Protect cylinders from physical damage. Store in cool, dry, well-ventilated area away from heavily trafficked areas and emergency exits. Do not allow the temperature where cylinders are stored to exceed 125°F (52°C). Cylinders should be stored upright and firmly secured to prevent falling or being knocked over. Full and empty cylinders should be segregated. Use a "first in - first out" inventory system to prevent full cylinders being stored for excessive periods of time.</p> <p>For additional storage recommendations, consult Compressed Gas Association's Pamphlets P-1, G-6, G-6.1, and G-6.2</p>			
SPECIAL PACKAGING RECOMMENDATIONS			
<p>Dry carbon dioxide can be handled with most common structural materials. Moist carbon dioxide is corrosive by its formation of carbonic acid. For these applications, 316, 309 and 310 stainless steels may be used as well as Hastelloy® A, B and C and Monel®. Ferrous nickel alloys are slightly corroded.</p> <p>At normal temperatures carbon dioxide is compatible with most plastics and elastomers.</p>			
OTHER RECOMMENDATIONS OR PRECAUTIONS			
<p>Compressed gas cylinders should not be refilled except by qualified producers of compressed gases. Shipment of a compressed gas cylinder which has not been filled by the owner or with his (written) consent is a violation of Federal Law (49CFR).</p> <p style="text-align: right;">(Continued on Page 4)</p>			

*Various Government Agencies (i.e. Department of Transportation, Occupational Safety and Health Administration, Food and Drug Administration and others) may have specific regulations concerning the transportation, handling, storage or use of this product which will not be reflected in this data sheet. The customer should review these regulations to ensure that he is in full compliance.

Carbon Dioxide

SPECIAL PRECAUTIONS

OTHER RECOMMENDATIONS OR PRECAUTIONS: (Continued)

Always secure cylinders in an upright position before transporting them. NEVER transport cylinders in trunks of vehicles, enclosed vans, truck cabs or in passenger compartments. Transport cylinders secured in open flatbed or in open pick-up type vehicles.

Reporting under SARA, Title III, Section 313 not required.

NFPA 704 No. for gaseous carbon dioxide = 2 0 0 None